

RECEIVED
APR 20 1960

WATER WELL REPORT

JACK
7290

36/2W-25Q

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER STATE OF OREGON

G1731

State Well No.

State Permit No.

(1) OWNER:

Name F. E. Griffiths
Address 6198 Table Rock Rd
Central Point ORE

(2) LOCATION OF WELL:

County Jackson Owner's number, if any—
N 1/2 SW 1/4 SE 1/4 Section 25 T. 36 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner
Well is located 1007' N. & 257' E.
from the S 1/4 cor. sec 25

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
18" Diam. from 0 ft. to 36 ft. Gage Case
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
36 perforations from 25 ft. to 36 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
_____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 3 ft.
Material used in seal— Concrete
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 9.5 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] F. E. Griffiths Date 4-5, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 18 inches.
Depth drilled 36 ft. Depth of completed well 36 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0'	3'
Hard Pan	3'	14'
Sand Gravel (Water)	14'	16'
Silty Clay	16'	21'
Sand & Water	21'	23'
Clay	23'	34'
Sand-Gravel (Water)	34'	36'

Work started 4-5 1960 Completed 4-5 1960

(13) PUMP:

Manufacturer's Name Bankley
Type: 2" x 1.5" centrifugals H.P. 3.0 + 2.0 elec

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Shand Bros Drilling Co.
(Person, firm, or corporation) (Type of print)
Address 412 N 3rd Central Point
Driller's well number _____
[Signed] Wayne W. Shand
(Well Driller)
License No. 4-544 Date 4-5, 1960