

RECEIVED

MAY 13 1966

JACK 8868

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER

STATE OF OREGON

(Please type or print)

State Well No. 36/3w-23
State Permit No.

(1) OWNER:

Name MR. BURTON ALBRECHT
Address RT. 1 Box 349 CENTRAL POINT ORE

(2) LOCATION OF WELL:

County JACKSON Driller's well number
1/4 1/4 Section 23 T. 36S R. 3 W. W.M.
Bearing and distance from section or subdivision corner
APPROX. 400 FEET SOUTH OF HIGHWAY 99
APPROX. 1 MILE EAST OF GOLD HILL CITY LIMITS.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 36 ft. Gage 250
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE SLURRY
Depth of seal 36 ft. Was a packer used? No
Diameter of well bore to bottom of seal 6 in.
Were any loose strata cemented off? [] Yes [] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 5/7/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 28 gal./min. with 29 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 37 ft. Depth of completed well 37 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: SOIL, BROWN (0-3); SOIL, DECOMPOSED WITH SMALL GRAVEL (3-35); SAND WATER BEARING (35-37)

Work started 5-7 1966 Completed 5-7 1966
Date well drilling machine moved off of well 5-7 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MARTINSON WELL DRILLING (Person, firm or corporation) (Type or print)
Address RT. 1 Box 602 FAHLE POINT ORE
Drilling Machine Operator's License No. 21
[Signed] J. W. Martinson (Water Well Contractor)
Contractor's License No. 406 Date 5-7 1966