

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

FEB 9 1979 STATE OF OREGON
WATER RESOURCES DEPT.
SALEM, OREGON (Do not write above this line)

Jeff
260

State Well No. 95/15E-20cc
State Permit No. _____

(1) OWNER:

Name RON OCHS
Address RT 1 B.O.X (GATEWAY RT)
MADRAS ORE. 97741

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12" Diam. from +2 ft. to 96 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" _____ " _____ " _____
" (FLOWING) " _____ " _____
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow 200 g.p.m.
Temperature of water 60 Depth artesian flow encountered 200 ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 27 sacks
How was cement grout placed? PRESSURE GROUT
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County JEFFERSON Driller's well number _____
S.E. 1/4 S.W. 1/4 Section 20 T. 9 S. R. 15 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 200 ft.
Static level FLOWING ft. below land surface. Date 2-6-79
Artesian pressure 1 lbs. per square inch. Date 10-6-78

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 210 ft. Depth of completed well 210 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Top 20' -</u>	<u>0</u>	<u>1</u>	
<u>Broken Lava & Brown Clay</u>	<u>1</u>	<u>36</u>	
<u>Blue Grey Clay</u>	<u>36</u>	<u>150</u>	
<u>Green Clay Stone</u>	<u>150</u>	<u>210</u>	
<u>Water-bearing level</u>	<u>170</u>	<u>210</u>	

Work started 9-27 1978 Completed 1-20 1979
Date well drilling machine moved off of well 2-6 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William G. Allen Date 2-6, 1979
(Drilling Machine Operator)

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Orvil Beaman (Person, firm or corporation) (Type or print)
Address 1100 NE Nassau St. Madras, Ore.
[Signed] Orvil Beaman (Water Well Contractor)
Contractor's License No. 666 Date 2-6, 1979