NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT UEIVED

STATE OF OREGON AUG 5 1981 State Well No. ..

(Please type or WATER RESOURCES DEPT Permit No. (Do not write above this lin SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Homestead Investment Co.	County Jefferson Driller's well n	umber D-226-	79
Address 1204 Chestnut St.	S.E. 34 S.W. 34 Section 6 T.10S	r. 13E	W.M
Madras, Oregon	Bearing and distance from section or subdivis	ion corner	
(2) TYPE OF WORK (check):			
New Well			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	vell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 123	3	ft
Rotary Driven Domestic M Industrial Municipal	Static level 80 ft. below land	surface. Date 5-	10-79
Cable Jetted		re inch. Date	
(CASING INSTALLED: Threaded Welded W	(12) WELL LOG: Diameter of well	below casing	8
8 "Diam from ±1 ft to 122 ft Gage .250	Depth drilled 250 ft. Depth of comp		ft
6 " Diam from 110 ft to 250 ft Gage 188	Formation: Describe color, texture, grain size		
	and show thickness and nature of each stratu with at least one entry for each change of forms		
PERFORATIONS: Perforated? ☑ Yes ☐ No.	position of Static Water Level and indicate prin		
pe of perforator used cutting torch	MATERIAL	From To	SWL
Size of perforations 1/4 in. by 6 in.	topsoil	0 3	
480 perforations from 123 ft. to 182 ft.	brown clay	3 68	
perforations from ft. to ft.	_blue_clay	68 84	
perforations from ft. to ft.	claystone gray	84 123	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	rock-decomp-clay-water	123 182	80
Manufacturer's Name	gray claystone	182 218	
Type Model No.	brownish blue clay	218 250	
Diam Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? ☐ Yes ☐ No If yes, by whom?			
Yield: 52 gal./min. with totalft. drawdown after l_2^1 hrs.			
" " "			
" " "			
Bailer test gal./min. with ft. drawdown after hrs.		 	
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 5-2 1979 Complet	cd 5-10	1979
(9) CONSTRUCTION:	Date well drilling machine moved off of well	5-10	19 8 9
Well scal—Material used Cement	Drilling Machine Operator's Certification:		
Well scaled from land surface to 20 ft.	This well was constructed under my Materials used and information reported	direct super	vision. to my
Diameter of well bore to bottom of seal 12 in.	best knowledge and belief	40000 410 0140	
Diameter of well bore below seal	[Signed] And Connection (Drilling Machine Operator)	Date 5-11	., 19.79
Number of sacks of cement used in well seal 18 sacks	Drilling Machine Operator's License No. 883		
How was cement grout placed?DUMPEQ			
	Water Well Contractor's Certification:		
	This well was drilled under my jurisd		eport is
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and bel		
Did any strata contain unusable water? Yes X No	NameS. & M. Drilling & Supply (Person, firm or corporation)		
Type of water? depth of strata	Address 399 S.E. Walnut, Canby,	, Oregon 970	13
Method of sealing strata off	[Signed] Matter Mas	12	
Was well gravel packed? ☐ Yes 🕱 No Size of gravel:	(Water Well Contu	_	
Gravel placed from ft. to ft.	Contractor's License No. 497 Date	5-11	, ₁₉ 79