WATER WELL REPORT
STATE OF OREGON

JEFF 790 J

RECEIVED
JUL 21 1981
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 13/12E-3 CCB

State Permit No. G-7313

(1) OWNER:
Name Robert Selby
Address Grizzly Star Rt. 9 7/74
City Madras State Ore

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
☒ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: ☐ Withdrawal ☐ Reinjection ☐

CASING INSTALLED:
Steel ☒ Plastic ☐
Threaded ☐ Welded ☒
8 " Diam. from +1 ft. to 75 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Factory
Size of perforations 4 in. by 1/8 in.
860 perforations from 20 ft. to 75 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Maphet Well Drilling
Yield: 105 gal./min. with 30 ft. drawdown after 1 hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 56 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 50° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used Cement
Well sealed from land surface to 18' ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? Pumped
Was pump installed? Yes Type Sub HP 7½ Depth 65 ft.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel:
Gravel placed from 18 ft. to 75 ft.

(10) LOCATION OF WELL:
County Jefferson Driller's well number 225
NE ¼ NW ¼ Section 3 T. 13S R. 14E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: Government Lot #3

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 20 ft. below land surface. Date 6 26 81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8
Depth drilled 75 ft. Depth of completed well 75 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Top Soil	0	1	
Gravel & Yellow Clay	1	10	
Broken Sandstone	10	55	
Gravel	55	57	
Brown Sandstone	57	75	

Work started 6-8 19 81 Completed 6-20 19 81
Date well drilling machine moved off of well 6 26 19 81

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Jerome K. Emmons (Drilling Machine Operator) Date 6-26, 1981
Drilling Machine Operator's License No. 1417

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name (Person, firm or corporation) (Type or print) MAPHET WELL DRILLING
Address PLR 500 Davis Road PRINEVILLE, OREGON 97754
[Signed] Donald Maphet (Water Well Contractor)
Contractor's License No. 584 Date 7-17, 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690