## WATER WELL REPORT STATE OF OREGON

RECEIVED JOSES

State Well No. 5

WATER RESOURCES DEPT SALEM, OREGON

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name J. D. SMITH	County JOSEPHINE Driller's well number
Address 2325 HIGHLAND	NW 45E 4 Section 6 T.365 R. 5W W.M.
City GRANTS PASS State DRE	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: SAME
New Well □ Deepening Reconditioning A Abandon □	(11) XVADED LEXTS C. 1 / 1 II
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
Navy Air Driven Domestic Mandustrial Municipal	Static level 25 ft. below land surface. Date 8 - 20 - 80
Rotary Mud   Dug   Irrigation   Test Well   Other   Cable   Bored   Thermal: Withdrawal   Reinjection	Artesian pressure lbs. per square inch. Date  (12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel   Plastic   Threaded   Welded   Welded	Depth drilled //O ft. Depth of completed well //O ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	
	MATERIAL From To SWL
	GRADITE-BLK YLONT 102 140 25
(6) PERFORATIONS: Perforated? ☐ Yes No Type of perforator used	
Size of perforations in. by in.	
perforations from ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS:       Well screen installed? □ Yes □ No         Manufacturer's Name       Model No.         Type       Model No.         Diam.       Slot Size         Set from       ft. to         Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ☐ If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	<u> </u>
test 150 gal./min. with drill stem at 140 ft. 2 hrs.	· · · · · · · · · · · · · · · · · · ·
belier test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
Temperature of water 55° Depth artesian flow encountered ft.	Work started 8-19 19 80 Completed 8-20 19 80
(9) CONSTRUCTION: Special standards: Yes \( \text{No} \( \text{D} \)	Date well drilling machine moved off of well 8-20 1980
Well seal—Material used MOT DISTURBED  Well sealed from land surface to ft.  Diameter of well bore to bottom of seal in.  Diameter of well bore below seal in.	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  [Signed] (Drilling Machine Operator)  Date 1980
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No.
How was cement grout placed?	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ►No Plugs Size: location ft.	Name OCDYN HOS WELL DRILLING (Person, firm or corporation), (Type or print)
Did any strata contain unusable water?   Yes No	Address 2075 NW VINE- CLANTS PASS
Type of Water? depth of strata	10: 11 2 75.77 (Blanca
Method of sealing strata off	[Signed] Water Well Contractor
Was well gravel packed? ☐ Yes No Size of gravel:	Contractor's License No. 6. 43 Date 9-6 ,190
Gravel placed from ft. to ft.	