

WATER WELL CONTRACTOR original and first copy this report are to be filed with the

WATER WELL REPORT

RECEIVED JAN 29 1973

36S/5W-29 aa

ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

JOSE 1054

STATE OF OREGON STATE ENGINEER SALEM, OREGON (Do not write above this line)

State Well No. State Permit No.

(1) OWNER:

Name Doug Robertson Address 2464 Cloudlawn Dr. Sparks Pass Ore

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Cable [] Dug [] Driven [] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

6" Diam. from 0 ft. to 40 ft. Gage 550

PERFORATIONS:

Perforated? [] Yes [x] No. Type of perforator used Size of perforations in. by in.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal-Material used Cement Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 7 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 10 sacks

(10) LOCATION OF WELL:

County Josephine Driller's well number NE 1/4 NE 1/4 Section 29 T.36S R. 5W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30 ft. Static level 8 ft. below land surface. Date 7-23-73 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Depth drilled 78 ft. Diameter of well below casing 6 ft. Depth of completed well 78 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, From, To, SWL. Rows: Brown clay & medium gravel, Brown clay & granite, Med-Hard Granite.

Work started 1-22 1973 Completed 1-22 1973 Date well drilling machine moved off of well 1-22 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Robert K. Earnest Date 1-23, 1973

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name Geo. McElanahan Well Drilling (Person, firm or corporation) (Type of print) Address 730 N.E. Elida Dr. Sparks Pass Ore [Signed] George McElanahan (Water Well Contractor) Contractor's License No. 422 Date 1-23, 1973