WATER WELL REPORT
STATE OF OREGON

RECEIVED
SEP 04 1981
WATER RESOURCES DEPT
SALEM, OREGON

Jose 10658

State Well No. 39/5W-10 aC

State Permit No. .....

(1) OWNER:
Name Wight Atkins
Address 1912 E. FORK RD.
City Williams State ORE. 97544

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED: Steel ☒ Plastic ☐ Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 60 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test 20 gal./min. with drill stem at 50 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53° Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☒
Well seal—Material used Cement Grout
Well sealed from land surface to 23 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
How was cement grout placed? Grout Pump
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number 113
SW ¼ NE ¼ Section 10 T. 39 R. 5W W.M.
Tax Lot # 900 Lot Blk Subdivision
Address at well location: 1912 E. Fork Rd.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 70 ft.
Static level 20 ft. below land surface. Date 8/26/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Granite Soft	0	8	
Gray Granite & Clay	8	16	
Gray Clay	16	28	
Gray Granite & Clay	28	50	
Gray Granite w/Quartz Seam	50	80	

Work started 8/26 19 81 Completed 8/26 1981
Date well drilling machine moved off of well 8/26 1981

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Anderson (Drilling Machine Operator) Date 8/28, 19 81
Drilling Machine Operator's License No. 809

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name McCLANAHAN WELL DRILLING (Person, firm or corporation) (Type or print)
Address 141 N.E. BEACON DR. GRANTS PASS, OR. 97526
[Signed] K. McClanahan (Water Well Contractor)
Contractor's License No. 727 Date 8/28, 19 81

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690