

WATER WELL REPORT

RECEIVED

STATE OF OREGON

SEP 25 1981

WATER RESOURCES DEPT SALEM, OREGON

Jose 1073 State Well No. 375/5W-25dc State Permit No.

(1) OWNER:

Name GUS CAMERON Address 588 MISSOURI FLAT RD. City GRAND PASS State OR 97526

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [ ] Rotary Mud [ ] Dug [ ] Bored [ ] Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] Thermal: Withdrawal [ ] Reinjection [ ]

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel Threaded [ ] Plastic Welded [X] 6" Diam. from 0 ft. to 80 ft. Gauge 250

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? [ ] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [ ] Yes [X] No If yes, by whom? Field: gal./min. with ft. drawdown after hrs. Air test 60 gal./min. with drill stem at 62 ft. 1 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [ ] No [X] Well seal—Material used CEMENT GROUT Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 7 sacks How was cement grout placed? GROUT PUMP Was pump installed? n.d. Type HP Depth ft. Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [X] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JOSEPHINE Driller's well number 120-3 SW 1/4 SE 1/4 Section 25 T. 375 R. 5W W.M. Tax Lot # 16.06 Lot Blk Subdivision Address at well location: 588 MISSOURI FLAT RD.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 88 ft. Static level 43 ft. below land surface. Date 9/18/81 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 116 ft. Depth of completed well 116 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN GRANITE, w/clay (0-20), BROWN CLAY (20-30), BROWN GRANITE MED-HARD (30-70), GRAY GRANITE - HARD (70-85), GRAY FRAC. GRANITE (85-116).

Work started 9/17 1981 Completed 9/18 1981 Date well drilling machine moved off of well 9/18 1981

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Robert [Name] Date 9/23, 1981. Drilling Machine Operator's License No. 809

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name McClana Dan Well Drilling Address 141 N.E. Beacon Dr Grand Pass, OR 97526 [Signed] Dan [Name] (Water Well Contractor) Contractor's License No. 727 Date 9/23, 1981