WATER WELL REPORT
STATE OF OREGON

gpd 11256

RECEIVED
APR 9 1984
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 36S/5W-19bc

PLEASE TYPE or PRINT Permit No. .....

(1) OWNER:

Name: Joseph Speelman
Address: 313 Spruce St
City: Grants Pass, OR XXXXXX 97526 State

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED: Steel ☒ Threaded ☐ Plastic ☐ Welded ☒

6" Diam. +1 ft. to 80 ft. Gauge .250

" Diam. ft. to ft. Gauge

WELD-ON INSTALLED:

" Diam. ft. to ft. Gauge

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No

Type of perforator used: Torch
Size of perforations: 1/4 in. by 8 in.
40 perforations from 61 ft. to 79 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 22 gal./min. with 27 ft. drawdown after 1 hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☒

Well seal—Material used: Cement
Well sealed from land surface to: 18 ft.
Diameter of well bore to bottom of seal: 8 10X in.
Diameter of well bore below seal: 8 in.
Number of sacks of cement used in well seal: 20 sacks
How was cement grout placed? Tremie Pipe

Was pump installed? Yes Type Sub HP 1½ Depth 75 ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs: Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County: Josephine Driller's well number
SW ¼ NW ¼ Section 19 T. 36S R. 5 W.M.
Tax Lot # 300 Lot Blk Subdivision
Address at well location: 1313 Spruce St
Grants Pass, OR 97526

(11) WATER LEVEL: Completed well.

Depth at which water was first found 59 ft.
Static level 14 ft. below land surface. Date 3/16/84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing --

Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy silt	0	12	
Cemented sand and gravel	12	58	
Loose sand and small gravel	58	80	14
(Aquifer 58-80feet)			

Work started 3/15/84 Completed 3/21/84 19
Date well drilling machine moved off of well 3/21/84 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] ..... Date ....., 19.....

Bonded Water Well Constructor Certification:

Bond 28018140 (number) Issued by: Western Surtey (Surety Company Name)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ted Lund Drilling (Person, firm or corporation) (Type or print)
Address 635 Barbara Drive, Grants Pass, OR
[Signed] Ted Lund (Water Well Constructor)
Date 4/4/84, 19

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690