WATER WELL REPORT
STATE OF OREGON

JOSE 11322

RECEIVED
MAR 15 1984
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 38S/5W-34bc

State Permit No.

PLEASE TYPE or PRINT IN INK

(1) OWNER:
Name Lee Wendelbo
Address 264 Norton Rd
City Williams OR 97544 State

(2) TYPE OF WORK (check):
New Well XX Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air XX Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic XX Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel XX Plastic ☐
Threaded ☐ Welded ☐
6" Diam. from +1 ft. to 114 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
4" Diam. from -6 ft. to 206 ft. Gauge Class 160 PVC

(6) PERFORATIONS:
Perforated? ☐ Yes XX No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes XX No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes XX No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test 7 gal./min. with drill stem at 200 ft. 2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No XX
Well seal—Material used Cement
Well sealed from land surface to 110 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? Tremie Pipe

Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☐ Yes XX No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes XX No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes XX No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number
SW ¼ NW ¼ Section 34 T. 38 R. 5 W.M.
Tax Lot # 1201 Lot Blk Subdivision
Address at well location: Not Known TETHROW RD

(11) WATER LEVEL: Completed well.
Depth at which water was first found 138 ft.
Static level 120 ft. below land surface. Date 3/12/84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6 inch
Depth drilled 206 ft. Depth of completed well 206 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	1	
Decomposed Granite	1	97	
Hard Granite	97	138	
Fractured Ganite	138	149	120
Hard Tombstone Granite	149	206	120

Work started 3/9/84 19 Completed 3/12/84 19
Date well drilling machine moved off of well 3/12/84 19

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ted Lund Date 3-14-84

Bonded Water Well Constructor Certification:
Bond 28018140 (number) Issued by: Western Surety Co (Surety Company Name)
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ted Lund Drilling (Person, firm or corporation) (Type or print)
Address 635 Barbara Dr. Grants Pass, OR 97526
[Signed] Ted Lund Water Well Constructor
Date 3-14-84, 19

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690