WATER WELL REPORT
STATE OF OREGON

RECEIVED
DEC 16 1983
WATER RESOURCES DEPT.
SALEM, OREGON

NOV 4 1983
WATER RESOURCES DEP.

State Well No. 39S/5W-5c6

State Permit No. 59491326

PLEASE TYPE or PRINT IN INK

(1) OWNER:
Name JERRY BLACK
Address 4415 CEDAR FLAT RD.
City WILLIAMS State OR

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☑ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: ☐ Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel Threaded ☑ ☐ Plastic Welded ☐ ☑
6 " Diam. from +1 ft. to 39 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
4 " Diam. from 20 ft. to 120 ft. Gauge 160

(6) PERFORATIONS:
Perforated? ☑ Yes ☐ No
Type of perforator used SAW
Size of perforations 1/8 in. by 12 in.
60 perforations from 80 ft. to 140 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test 20 gal./min. with drill stem at 140 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☑
Well seal—Material used Cement
Well sealed from land surface to 39 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? pumped down ANNULAR SPACE
Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number 45-83
NW ¼ SW ¼ Section 5 T. 39S R. 5W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.
Depth at which water was first found 80 ft.
Static level 24 ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 140 ft. Depth of completed well 140 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
			24
CLAY	0	33	
GRANITE (DECOMPOSED)	33	140	

Work started 7-25 19 83 Completed 7-25 19 83
Date well drilling machine moved off of well 7-25 19 83

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dan Carter Date 8-10, 19 83

Bonded Water Well Constructor Certification:
Bond (number) Issued by: Pacific Reliance Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ART CARTER WELL DRILLING (Person, firm or corporation) (Type or print)
Address 240 JOHNSON RD. MEDFORD
[Signed] Art Carter Water Well Constructor
Date 8-15, 1983

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690