Per WWC: #8 - 15 gpm with 20 ft drawdown after 1 hr. CWW 5/1/84

Letter apologizing for late log rec. 4/5/84

WATER WELL REPORT
STATE OF OREGON

RECEIVED APR 9 1984 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 11535 Jose 38s/7W-7cc

State Permit No.

PLEASE TYPE or PRINT IN INK

(1) OWNER:
Name David Linderman
Address 1983 Deer Creek Road
City Selma, OR State

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel ☒ Plastic ☐
Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 105 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
4" Diam. from ft. to ft. Gauge Class 160

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
15 perforations from 100 ft. to 104 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used Cement
Well sealed from land surface to 92 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? Tremie Pipe

Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number
SW ¼ SW ¼ Section 7 T. 38s R. 7W W.M.
Tax Lot # 302 Lot Blk Subdivision
Address at well location: 1983 Deer Creek Road
Selma, OR

(11) WATER LEVEL: Completed well.
Depth at which water was first found 100 ft.
Static level 55 ft. below land surface. Date 1/28/84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6 inch
Depth drilled 124 ft. Depth of completed well 124 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Red Clay	0	4	
Red clay and gravel	4	48	
Braown clay	48	60	
Grey clay and gravel	60	95	
Cemented grey gravel	95	112	
Lightly cemented & gravel	112	124	

Work started 1/27/84 19 Completed 1/28/84 19
Date well drilling machine moved off of well 1/30/84 19

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:
Bond 28018140 (number) Issued by: Western Surety Co. (Surety Company Name)
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ted Lund Drilling (Person, firm or corporation) (Type or print)
Address 635 Barbara Drive, Grants Pass, OR
[Signed] Ted Lund (Water Well Constructor)
Date Feb 1, 1984

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690