

RECEIVED

JUL 10 1984

WATER WELL REPORT
STATE OF OREGON

JOS 2
11567

WATER RESOURCES DEPT
PLEASE TYPE or PRINT IN INK
SALEM, OREGON

State Well No. 365/6W-236c
State Permit No.

(1) OWNER:

Name Bill Deakin
Address Danelle Lane
City Grants Pass State ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

Community Well

(5) CASING INSTALLED:

Steel Threaded Plastic Welded

6" Diam. from 7.12" ft. to 7.86" ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Is a pump test made? Yes No If yes, by whom?
Field: gal./min. with ft. drawdown after hrs.
" " " " "
Air test 35 gal./min. with drill stem at 74 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 33 sacks
How was cement grout placed? Cement Pump

Was pump installed? No Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? Surface depth of strata 6' to 16'
Method of sealing strata off Cement
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number 706
SW 1/4 NW 1/4 Section 23 T. 36S R. 6W W.M.
Tax Lot # 5000 Lot Blk Subdivision
Address at well location: Danelle Lane
Grants Pass Oregon

(11) WATER LEVEL: Completed well.

Depth at which water was first found 32 ft.
Static level 5 ft. below land surface. Date 7-6-84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 114 ft. Depth of completed well 114 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	2	
Yellow Clay	2	6	
Sand & Gravel to 2"	6	16	
Yellow Clay Rock 2"	16	32	
Sand & Gravel to 2"	32	47	5
Cemented Sand & Gravel 3"	47	71	
Yellow Clay Rock 3"	71	88	
Hard Orange sand Granite	88	113	5
Fractured			
Black & White Granite	113	114	

Work started 7-3 1984 Completed 7-6 1984
Date well drilling machine moved off of well 7-6 1984

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] A. P. Buehler Date 7-7, 1984

Bonded Water Well Constructor Certification:

Bond (number) Issued by: Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name A. P. Buehler Burlington Drilling
(Person, firm or corporation) (Type or print)

Address P.O. Box 928 Merlin, Ore

[Signed] A. P. Buehler
Water Well Constructor

Date 7-7, 1984