

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

JOSE
 11697

RECEIVED

365/4W-2316

OCT 8 1984

PLEASE TYPE or PRINT IN INK

WATER RESOURCES DEPT (for official use only)

(1) OWNER:

Name Ron Nunn
 Address 3853 Leonard Rd.
 City Grants Pass State OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal: Withdrawal ReInjection
 Other: Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 6" Diam. from +2 ft. to 108 ft. Gauge .250
 " Diam. from ft. to ft. Gauge

LINER INSTALLED:

Steel Plastic
 Threaded Welded

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot Size Set from ft. to ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 gal./min. with ft. drawdown after hrs.
 Air test 105 gal./min. with drill stem at 105ft. 1 hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water 57 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used Cement
 Well sealed from land surface to 30 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Amount of sealing material 9 sacks pounds
 How was cement grout placed? Pumped
 Was pump installed? No Type HP Depth ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? Surface depth of strata 8'-15'
 Method of sealing strata off Cemented
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Josephine NW 1/4 SE of Section 23 of
 Township 36, Range 6W, WM.
 (Township is North or South) (Range is East or West)
 Tax Lot 3400 Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address) Well #2, Willow
States Mobile Home Park

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 109 ft.
 Static level 9 ft. below land surface. Date 10/3/84
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
 Depth drilled 125 ft. Depth of completed well 125 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	6	
Brown Clay, Decomposed Granite	6	18	
Brown Clay, Medium Gravel	18	30	
Tan Clay, Large Gravel	30	100	
Brown Clay	100	109	
Large Gravel, Sandy	109	125	9'
Aquifer	109	121	105 GPM

Date work started 10/2/84 /completed 10/3/84
 Date well drilling machine moved off of well 10/3/84 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Bob Quinn Date 10/4/19 84

(bonded) Water Well Constructor Certification:

Bond 2394665 Issued by: Western Surety Co.
 (number) (Surety Company Name)
 On behalf of Paquin Drilling Inc.
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Bob Quinn
 (Water Well Constructor)

(Dated) 10/4/84

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report
 are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690