

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

Jose
 11733

RECEIVED

39S/SW-5.6E

PLEASE TYPE or PRINT IN INK

NOV 0 11984

(for official use only)

(1) OWNER:

Name Charles Mandeville
 Address 2220 Kincaid Rd
 City Williams State ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal Irrigation Withdrawal Reinjection
 Other: Piezometric Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 6" Diam. from +2 ft. to 112 ft. Gauge 250

LINER INSTALLED:

Steel Plastic
 Threaded Welded

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name Model No.
 Type Slot Size Set from ft. to ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 50 gal./min. with 145 ft. drawdown after 1 hrs.
 Air test 50 gal./min. with drill stem at 145 ft. 1 hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used CEMENT
 Well sealed from land surface to 25 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Amount of sealing material 9 sacks pounds
 How was cement grout placed? pumped
 Was pump installed? NO Type HP Depth ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel: ft.
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Josephine SALEM, OREGON W. of Section 5 of
 Township 39S, Range 5W, WM.
 (Township is North or South) (Range is East or West)
 Tax Lot 406 Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address)

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 113 ft.
 Static level 16 ft. below land surface. Date 10-2
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
 Depth drilled 150 ft. Depth of completed well 150 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BROWN CLAY	0	4	
BROWN CLAY medium TO LARGE Boulders	4	23	
Decomposed GRANITE SOFT FINE	23	92	
TOMBSTONE GRANITE VERY FIRM & FINE	92	150	16
AQUIFER	112	115	20gpm
RECEIVED	141	142	30gpm
OCT 29 1984			

WML DIST. 14 GRANTS PASS, ORE
 Date work started 10-24-84 /completed 10-25-84
 Date well drilling machine moved off of well 10-25 19 84

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Mike Pierce Date 10-25, 19 84

(bonded) Water Well Constructor Certification:

Bond 2394665 Issued by: WESTERN SURETY
 (number) (Surety Company Name)
 On behalf of PAQUIN Drilling INC
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Bob Quinn
 (Water Well Constructor)
 (Dated) 10-26-84

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690