

RECEIVED
NOV 9 1960
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

JOSE
1179

State Well No. 36/5W-30

State Permit No.

(1) OWNER:

Name Martin F. Horton
Address 1031 S. E. N. St
Grants Pass Ore

(2) LOCATION OF WELL:

County JOSEPHINE Owner's number, if any—
1/4 1/4 Section 30 T. 36 R. 5 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 50 ft. Gage 3.88
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 28 ft. below land surface Date 10-14-60
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Martin F. Horton Date 10-14, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Bailer test 8 gal./min. with 10 ft. drawdown after 1 1/2 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 51 ft. Depth of completed well 51 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	2
Decomposed Grt	2	27
Boulders 1 gr	27	36
Cement gr	36	50
Water gravel	50	51

Work started 10-12-1960 Completed 10-14-1960

(13) PUMP:

Manufacturer's Name none
Type: _____ H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pat Flynnot Drilling Co
(Person, firm, or corporation) (Type or print)

Address 2553 Redwood Ave

Driller's well number _____

[Signed] J. Earnest
(Well Driller)

License No. 51 Date 10-14, 1960