## WATER WELL REPORT STATE OF OREGON

DEC 1 4 1982

State Well No.	3.65	5w-	19ch
		1	,

WATER RESOURCES DEPT.

State Well No.	365 5w	-17cb
----------------	--------	-------

State Permit No.

	SALEM, UREGUN
(1) OWNER:	(10) LOCATION OF WELL:
Name JOSEPHINE Co. FAIR	County TOSE Driller's well number
Address P.O. BOX 672	NW 4 SW4 Section 19 T. 365 R. 5 W W.M.
City GRANTS PASS. State OR	Tax Lot # Lot Blk Subdivision
	Address at well location: FAIR EROUNDS
(2) TYPE OF WORK (check):	BY FOOT BALL FIELD
New Well	(11) WATER LEVEL: Completed well.
f abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
	Static level 29 ft. below land surface. Date //-/>
Rotary Air Driven	Artesian pressure lbs. per square inch. Date
Cable   Bored   Thermal: Withdrawal   Reinjection	(12) WELL LOG: Diameter of well below casing
5) CASING INSTALLED: Steel 🗡 Plastic 🗆	Depth drilled 180 ft. Depth of completed well 170 ft.
Threaded  Welded	Formation: Describe color, texture, grain size and structure of materials; and show
8 "Diam from +2 ft to 170 ft Gauge .025	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
•	
(6) PERFORATIONS: Perforated? X Yes  \( \square\) No	COBBLES & BOULPER
Type of perforator used TOURCH	14112 00 1151 00 25 110 100
Size of perforations 6 in. by 18 in.	SAND, GRAVEL, COEBUS 140 180
48 perforations from 155 ft. to 120 ft.	4 BOUL PERS
perforations from	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed?   Yes  No	
Manufacturer's Name	
Type Model No	
Diam. Slot Size Set from ft. to ft. to	
Diam. Slot Size Set from ft. to ft.	<u>:</u>
(8) WELL TESTS:  Drawdown is amount water level is lowered below static level	
below static level	
Was a pump test made? ☐ Yes 🏋 No If yes, by whom?	-
d: gal./min. with ft. drawdown after hrs.	
AIR TEST 150 " 169 1/2"	
Air test /25 gal./min. with drill stem at /54 ft. 1½ hrs.	
Bailer test gal/min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water 55° Depth artesian flow encountered ft.	Work started // -/6 19 8 2 Completed // -24 19 8
(9) CONSTRUCTION: Special standards: Yes \(\sigma\) No \(\text{NO}\)	
Wolf South State of the State o	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and helief.  [Signed]
Diameter of well bore below seal	(Drilling Machine Operator)
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No. 822
How was cement grout placed? PUMPED	
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed? Type HP Depth ft	
Was a drive shoe used? 🎢 Yes 🗆 No Plugs Size: location ft	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? 🗆 Yes 🕱 No	(Person, firm or corporation) (Type or print)  Address 2060 VIWE ST
Type of Water? depth of strata	7200
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes ▼No Size of gravel:	
Control of the state of the sta	- Contractor's License No