

RECEIVED

JOSE 12417 38e/SW-33ca

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765) WATER RESOURCES DEPT

JUL 21 1986

(1) OWNER:

Name Raymond Watts, Address 10785 Pninsular Ave., City Cupertino, State CA, Zip 95014

SALEM, OREG #2 Owner's Well Number: #2

(2) TYPE OF WORK:

[X] New Well [] Deepen [] Recondition [] Abandon

(3) DRILL METHOD:

[X] Rotary Air [] Rotary Mud [] Cable [] Other

(4) PROPOSED USE:

[X] Domestic [] Community [] Industrial [] Irrigation [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 80 ft.

Special Standards date of approval

Table with columns: HOLE Diameter, SEAL P.C., Amount sacks or pounds. Row 1: 10, 0, 18, P.C., 0, 18, 6 sacks. Row 2: 6, 18, 80

How was seal placed? Method [] A [] B [X] C [] D [] E

[] Other

Backfill placed from ft. to ft. Material

Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6, +2, 55, 250, [X], [], [X], []

Final location of shoe(s) 55

(7) PERFORATIONS/SCREENS:

[] Perforations Method [] Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Yield gal/min, Pumping level, Drill stem at, Time 1/2 hr. Row 1: 35, 80, 1 hr. Row 2: 25, 55

Temperature of water 51.4 Depth Artesian Flow Found

Was a water analysis done? [X] Yes By whom

Did any strata contain water not suitable for intended use? [] Too little

[] Salty [] Muddy [] Odor [] Colored [] Other

Depth of strata:

(9) LOCATION OF WELL by legal description:

County Joseph, Latitude, Longitude, Township 38 N or S, Range 5 W E or W, WM, Section 33 SW 1/4 NE 1/4, Tax Lot 103, Lot, Block, Subdivision, Street Address of Well (or nearest address) 1011 Tetherow Rd.

(10) STATIC WATER LEVEL:

13 ft. below land surface. Date 7-2-86, Artesian pressure lb. per square inch. Date

(11) WELL LOG:

Ground elevation

Table with columns: Material, From, To, WB?, SWL. Rows: Decomposed granite, soft (0-38); Decomposed granite, black, white, firm (38-80); Aquifer (62-80) with WB? 35 and SWL 13.

RECEIVED

JUL 17 1986

WIL. DIST. 14 GRANTS PASS, ORE.

Date started 7-2-86 Completed 7-2-86

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Michael L Pierce Date 7-9-86

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Bob Quinn Date 7-9-86

Company Paquin Drilling, Inc. Co. Job No.