JOSE 15827

OBSERVATION WELL

STATE ENGINEER Salem, Oregon

15821

Well Record

STATE WELL NO. 39/5W-6K(1)
COUNTY Josephine APPLICATION NO. GR-90

OWNER: Brown Bros. Lumber Co. Ir	MAILING ADDRESS:		
		Grants Pass. Oregon	
LOCATION OF WELL: Owner's No. #1 NW 14 SE 14 Sec. 6 T. 39 S., R. 5	É. W., W.M.		
Bearing and distance from section or subdivision	1.		
corner N 54° 30' W 450' to center of Se	ec. 6		
		K1 •	
Altitude at well 1695 Interpolated			
TYPE OF WELL: Drilled Date Constructed	6/1/52		
Depth drilledDepth cased	+3'	Section6	
CASING RECORD: 12 inch casing set from 0 to 43' 8 inch casing set from 0 to 76'			
FINISH: 58 perforations 3/16" x 4" set from 43 AQUIFERS:	3 to 73 feet		
Rock (granite) from 76 to 170			
WATER LEVEL: 31 feet below land surface 6/18/52			
PUMPING EQUIPMENT: TypeDoward Je Capacity 20 G.P.M.	et .	н.р. 19	2
WELL TESTS: Drawdown 80' ft. after	hours	18	G.P.M.
Drawdown ft. after	hours		G.P.M.
SOURCE OF INFORMATION Registration	on Statement GR-90	Grants Pass, Oregon	
Logx Water Level Measurements	Chemical Anal	ysis Aquifer Test	
REMARKS:			

JOSE 15827

STATE ENGINEER Salem, Oregon

State Well No.	39/5W-6K(1)
County	Josephine
Application No.	GR-90

Well Log

5		1 to 1	_
riller: Paquin & Story Grants Pass	Date Drille	ed 6/1/52)
CHARACTER OF MATERIAL	(Feet below From	and surface)	Thickness (feet)
Clay and boulders	0	43	43
Gravel, with clay	43	76	33
		·	
Rock, granitoid (?) blue color	76	170	94
			
•			
			
			-