

JOSE 1655

WATER WELL REPORT STATE OF OREGON

State Well No. 37/5W-18 JB State Permit No.

(1) OWNER: Name Josephine County School District Address Court House Annex Grants Pass, Oregon

(2) LOCATION OF WELL: County Josephine Owner's number, if any-- SW 1/4 SE 1/4 Section 18 T. 37S R. 5W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New well [] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: Threaded [] Welded [] 10" Diam. from 0 ft. to 31 ft. Gage 1/4 Wall 8" Diam. from 0 ft. to 125'8" ft. Gage 1/4 Wall

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used SIZE of perforations 1/4 in. by 2 in. 92 perforations from 98 ft. to 121 ft.

(8) SCREENS: Well screen installed [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [x] Yes [] No To what depth? 31 ft. Material used in seal-- Cement Grout Did any strata contain unusable water? [] Yes [x] No Type of water? Depth of strata Method of sealing strata off


(10) WATER LEVELS: Static level 11 ft. below land surface Date Jan 10, 1962 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Elmer W. Fleming Date 2/6, 1962 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 17 gal./min. with 121 ft. drawdown after 1 1/2 hrs. Artesian flow g.p.m. Date Temperature of water 51 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG: Diameter of well 8 inches. Depth drilled 150 ft. Depth of completed well 150 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Clay & Boulders, River Run Rock, Clay, Small Round Rock, Fine, Sifty Sand, Clay, Rock, & Some Fine Sand, Rock & Serpentine.



Work started Jan 2, 1962 Completed Jan 10 1962

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. F. Paquin & Son (Person, firm, or corporation) (Type or print) Address 2820 South River Road Driller's well number [Signed] (Well Driller) License No. 275 Date Feb 1, 1962

(USE ADDITIONAL SHEETS IF NECESSARY)

Lincoln Savage Junior High School