WILLMAN

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
JUL 17 1968
STATE ENGINEER
SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Jose
1919

State Well No. 37/5w-36baad
State Permit No.
G-5095

owner's #3

(1) OWNER:
Name E E Willman Jack Bennett #3
Address 540 Rubble Rd Grants Pass Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 60' ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 10' ft. below land surface Date
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 60 gal./min. with 45 ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 50 Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Cement
Depth of seal 36 ft.
Diameter of well bore to bottom of seal 10" in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Josephine Driller's well number
¼ ¼ Section 36 T. 37S R. 5W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
LOAM - SANDY - DARK Brn	0	41'	—
CLAY Brn	41'	42'	—
Decomposed granit	42	55'	—
Fractured TOMBSTONE	55'	80'	10

Work started 6-12 1968 Completed 6-12 1968
Date well drilling machine moved off of well 6-12 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Carl Overstreet (Drilling Machine Operator) Date 6-15, 1968
Drilling Machine Operator's License No. 427

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R F Paquin Drilling Co (Person, firm or corporation) (Type or print)
Address 2820 So. River Rd Grants Pass Ore
[Signed] R F Paquin (Water Well Contractor)
Contractor's License No. 575 Date July 12, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)