STATE	ENGINEER
Saler	m, Oregon



STATE WELL NO 35/6W-10Q COUNTY JOSEPHINE APPLICATION NO. GR-696

OWNER: Melvin Toothman	MAILING ADDRESS:			
	CITY AND	Grants Pass, Oregon		
LOCATION OF WELL: Owner's No.	SIAIE:			
SW 1/4 SE 1/4 Sec. 10 T. 35 S, R. 6 W	`, W.M.	,		
Bearing and distance from section or subdivision				
corner 1875' W. of Est. Gov. corner and 702	* N.		1	
Altitude at well				
TYPE OF WELL: Drilled Date Constructed 195	2		N ₂	
Depth drilled 195 Depth cased 192		Section		
CASING RECORD:				
8-inch				
FINISH:				
a to a constant 2 man 6th of		from 80 to 19	2	
Casing perforated - 3 per ft s	stze # x J .	21011 00 00 17	•	
AQUIFERS:				
Topsoil, clay, rock and gravel				
WATER LEVEL: 50-feet				
PUMPING EQUIPMENT: TypePacific_sub	bmersible		H.P	<u>4</u>
Capacity 75 G.P.M.				
WELL TESTS: Drawdown10 ft. after	hours	Pumping 50		G.P.M.
Drawdown70 ft. after	hours	Pumping 80		G.P.M.
USE OF WATER <u>Irrigation</u> SOURCE OF INFORMATION <u>GR-2439</u>	Temp	°F		, 19
DRILLER or DIGGER				
ADDITIONAL DATA:				
Log X Water Level Measurements	Chemical Ar	ialysis	Aquiier Test	
REMARKS: Topsoil 8 8				
Clay & broken rock 52 60 Clay, brown & yellow 18 78				
Clay & gravel, yellow - some wat	er 32 11	.0		
Clay, yellow 27 137 Gravel & conglomerate & clay - w	ater 31 1	.68		
Gravel - strong water 27 19				