## WATER WELL REPORT STATE OF OREGON

KEGEIVED MAR 10 1983

WATER RESOURCES DEPT. State Permit No. SALEM, OREGON

State Well No.	355/	6W-14cc

	WW 302			
1) OWNER:	(10) LOCATION OF WELL:			
Name Paradise Guest Ranch	County Josephine Driller's well	number		
Address 7000 Monument Dr.	S.W. 4 S.W.4 Section 14 T. 35	R. 6		W.M.
City Grants Pass State OR	Tax Lot # 1600 Lot Blk	20	bdivision	
2) TYPE OF WORK (check):	Address at well location: 7000 Monumen	t Dr	·	
	Behad metal Shop buildio	90		
New Well   Deepening □ Reconditioning □ Abandon □  Reconditioning □ Abandon □	(11) WATER LEVEL: Completed we	ell.		
f abandonment, describe material and procedure in Item 12.	Depth at which water was first found		65	ft.
3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 15 ft. below la	and surface		3-8-8
Rotary Air 🕱 Driven 🗆 Domestic 🛣 Industrial 🗆 Municipal 🗆	Artesian pressure lbs. per square inch. Date			
Rotary Mud	(12) WELL LOG: Diameter of well below casing 6			
	Depth drilled 100 ft. Depth of c	_		.00 ft.
CASING INSTALLED: Steel X Plastic Threaded Welded X	Formation: Describe color, texture, grain size and stru		· · · · · · · · · · · · · · · · · · ·	
6"Diam. from+2ft. to58ft. Gauge	thickness and nature of each stratum and aquifer penet	trated, wit	h at least	t one entry
"Diam from ft. to ft. Gauge	for each change of formation. Report each change in p and indicate principal water-bearing strata.	osition of	Static W	ater Level
LINER INSTALLED:	MATERIAL			
		From	То	SWL
The state of the s	Brown Caly, Decomposed			
6) PERFORATIONS: Perforated? Twees I No	Granite	0	_5	•
ype of perforator used Saw	Decomposed Granite	5	51	
Size of perforations 1/4 in. by 10 in.	Decomposed Grantite		ا حر	
6.5. perforations from 80. ft. to 1.00. ft.	Fractured Tombstone	51	100	
perforations from ft. to ft.	220000000000000000000000000000000000000			<del></del>
perforations from ft. to ft. to ft.				
7) SCREENS: Well screen installed?   Yes XNo	Aquifer 30 GPM	65	72	15
Manufacturer's Name				
Type	35 GPM	83	92	15
Diam. Slot Size Set from ft. to ft.				
Diam. Slot Size Set from ft. to ft.				
8) WELL TESTS: Drawdown is amount water level is lowered below static level				
Vas a pump test made? ☐ Yes ☐ XNo If yes, by whom?				
d: gal./min. with ft. drawdown after hrs.				
u n u				
Air test 65 gal./min. with drill stem at 100 ft. 1 hrs.				
Bailer test gal./min. with ft. drawdown after hrs.				
Artesian flow g.p.m.				
perature of water 52 Depth artesian flow encountered ft.	Work started 3-7-83 19 Complete	a 3-8	8 <u>-83</u>	19
9) CONSTRUCTION: Special standards: Yes \( \text{No } \text{X} \)	Date well drilling machine moved off of well	3-8	8-83	19
Vell seal—Material used Cement	Drilling Machine Operator's Certification:			
Well sealed from land surface to20 ft.	This well was constructed under my direct su			
Diameter of well bore to bottom of seal1.0in.	and information reported above are true to my be	est know	ledge an	ıd belief.
Diameter of well bore below sealbin.	[Signed] MeAN (Drilling Machine Operator)		.טַבּיַּג	.ر.19. ب
Number of sacks of cement used in well seal9	Drilling Machine Operator's License No 14	62		
How was cement grout placed? Pumped	Water Well Contractor's Certification:			····
	This well was drilled under my jurisdiction	and this	report	is true to
Vas pump installed?	the best of my knowledge and belief.		, roboro	arue u
Vas a drive shoe used? M Yes □ No Plugs	Name Paguin Drilling Inc.		/T	print)
Did any strata contain unusable water?   Yes XNo	(Person, firm or corporation) Address .1840. Willow In Gra			
ype of Water? depth of strata	2.00	~~~~	. HANGE PEG.	, <del>7</del> 7 75
Method of sealing strata off	[Signed] (Water Well Contract	<u>ب</u>		
Was well gravel packed? ☐ Yes ☐ Yes ☐ Yes ☐ Size of gravel:	Contractor's License No. 6.7.5Date		}	10
Fravel placed from ft to ft	- Constitution is incomed two saying	بر ۲۰۰۰ ۱۰۰۰ ۲۰۰۰	<i>^</i>	, то