

RECEIVED

NOV 16 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER OF OREGON SALEM OREGON (Please type or print)

Jose 19372

State Well No. 35/6w-16

State Permit No.

(1) OWNER:

Name Josephine County School
Address 100 West House Army Units Pass
Fleming Site

(2) LOCATION OF WELL:

County Josephine Driller's well number
1/4 Section 16 T. 35S R. 6W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Rotary [X] Driven [ ]
Irrigation [ ] Test Well [ ] Other [ ] Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 70 ft. Gage 1/4
5" Diam. from 50 ft. to 135 ft. Gage 1/4

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No
Type of perforator used Yanch
Size of perforations 1/4 in. by 3" in.
240 perforations from 70 ft. to 130 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Grout
Depth of seal 48' ft. Was a packer used? No
Diameter of well bore to bottom of seal 9 5/8 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 9 ft. below land surface Date Sept 20
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom?
Yield: 100 gal./min. with 60 ft. drawdown after 4 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 130 ft. Depth of completed well 130' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include Red Clay, Boulder, Medium, Decomposed Granite, Fractured Sandstone, Sandstone, Granite.

Work started Sept 19 1966 Completed Sept 20 1966
Date well drilling machine moved off of well Sept 20 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.F. PAQUIN Drilling Co.
Address 2820 So. RIVER Rd. Grants Pass Ore
Drilling Machine Operator's License No. 422
[Signed] R.F. Paquin
Contractor's License No. 275 Date 11-15, 1966