RECEIVED
JAN 9 1985
WATER RESOURCES DEPT
SALEM, OREGON

Jose
19752

37S/5W-32ab

STATE OF OREGON
# WATER WELL REPORT
(as required by ORS 537.765)

PLEASE TYPE or PRINT IN INK

(for official use only)

## (1) OWNER:
Name SALLY SMITH
SHANNON
Address 1501 GRAYS CR. RD. 97527
City GRANTS PASS State OR.

## (2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:
Rotary Air ☑ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

## (4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐
Other: Piezometric ☐ Grounding ☐ Test ☐

## (5) CASING INSTALLED:
Steel ☑ Plastic ☐
Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 39 ft. Gauge .250
" Diam. from ft. to ft. Gauge

## LINER INSTALLED:
Steel ☐ Plastic ☑
Threaded ☐ Welded ☐
4" Diam. from 0 ft. to 120 ft. Gauge .160

## (6) PERFORATIONS:
Perforated? ☑ Yes ☐ No
Size of perforations 7/8 in. by 12 in.
100 perforations from 40 ft. to 120 ft.
perforations from ft. to ft.
perforations from ft. to ft.

## (7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

## (8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test 15 gal./min. with drill stem at 120 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

## (9) CONSTRUCTION:
Special standards: Yes ☐ No ☑
Well seal—Material used CEMENT
Well sealed from land surface to 39 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 12 sacks ☑ pounds ☐
How was cement grout placed? PUMPED DOWN ANNULAR SPACE

Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

## (10) LOCATION OF WELL by legal description:
County JOSEPHINE NW ¼ NE ¼ of Section 32 of
Township 37S (Township is North or South), Range 5W (Range is East or West), WM.
Tax Lot Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address)
1501 GRAYS CR RD
GRANTS PASS OR

## (11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 70 ft.
Static level 7 ft. below land surface. Date 9-12
Artesian pressure lbs. per square inch. Date

## (12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| CLAY | 0 | 9 | |
| BOULDERS | 9 | 32 | |
| GRANITE | 32 | 120 | 7 |

Date work started 9-12 /completed 9-12
Date well drilling machine moved off of well 9-13 19 84

**(unbonded) Water Well Constructor Certification (if applicable):**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Art Carter Date 11-16, 19 84

**(bonded) Water Well Constructor Certification:**
Bond 800528 (number) Issued by: CONT. BOND & INS. CO. (Surety Company Name)
On behalf of ART CARTER (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) Art Carter (Water Well Constructor)
(Dated) 11-16-84

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690