

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED

APR - 1 1970

WATER WELL REPORT

STATE ENGINEER OF OREGON
SALEM, OREGON

(Please type or print)
Do not write above this line

State Well No.

State Permit No.

38/5W-27

(1) OWNER:

Name Charles R. Babb
Address 1521 Miracle Lane Medford, Oregon 97501

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☒ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 28 1/2 ft. Gage 250

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Size of perforator used

Size of perforations	in.	by	in.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 3-5-70
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"

Ball test 11 1/2 gal./min. with 23 1/2 ft. drawdown after 1 hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 28 1/2 ft.
Diameter of well bore to bottom of seal 6" in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Josephine Driller's well number 41
1/4 1/4 Section 27 T. 38 S. R. 5 W. W.M.

Bearing and distance from section or subdivision corner
Ragan Rd. Williams, Oregon

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Granite	0	28 1/2	
Diorite	28 1/2	100	40
First Water at 55 Ft.			39 1/2
3/4 H.P. Sears Sub.			
Installed - (3-18-70)			
(3-21-70)			

Work started 2-25 1970 Completed 3-5 1970
Date well drilling machine moved off of well 3-23 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Paul Shultz Date 3-30, 1970
(Drilling Machine Operator)

Drilling Machine Operator's License No. 462

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Shultz Well Drilling (Type or print)
Address 517 Park Place #4 Medford, Ore 97501

[Signed] Paul Shultz (Water Well Contractor)

Contractor's License No. 458 Date 3-30, 1970