NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Jose 2235

NOV 6 1964

State Well No. 39/5W-9C

State Permit No.

(1) OWNER:
Name Mr Dale H Butler & Barbara S Butler
Address 555 Dawson Rd - Williams, Oregon

(2) LOCATION OF WELL:
County Josephine Driller's well number
NE ¼ Section 9 T. 39 R. 5 W.M.
Bearing and distance from section or subdivision corner

TL 301

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 94 ft. Gage 0.250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Gray
Size of perforations 1/16 in. by 3 in.
20 perforations from 0 ft. to 5 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal 2 Sacks Bentonite
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☒ Yes ☐ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 16 ft. below land surface Date Oct 16/64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 18 gal./min. with 57 ft. drawdown after 1½ hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing
Depth drilled 93 ft. Depth of completed well 93 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Gray silt	0	6
Gray granite	6	36
Broken granite	36	82
Yellow clay + quick sand	82	86
Yellow granite	86	93

Work started Oct 13 1964 Completed Oct 16 1964
Date well drilling machine moved off of well Oct 16 1964

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BROWNER'S WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 123 S.E. "I" Street Grants Pass, Oregon

Drilling Machine Operator's License No. 346

[Signed] Homer G. Browner
(Water Well Contractor)

Contractor's License No. 414 Date Oct 19, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)