

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
 SEP 7 - 1972 STATE OF OREGON
 STATE ENGINEER (Please type or print)
 SALEM, OREGON (Do not write above this line)

Jore
 2515

State Well No. 345/6W-33 ab
 State Permit No. 6-8001

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

(1) OWNER:

Name Jerry Hatfield
 Address Huber Rd.
Grant Pass Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded 250

" Diam. from 0 ft. to 82 ft. Gage
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used TORON
 Size of perforations 1/4 in. by 4 in.
24 perforations from 72 ft. to 80 ft.
 .. perforations from ft. to ft.
 .. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
 " " " "
 " " " "
 Bailer test 50 gal./min. with 60 ft. drawdown after 2 1/2 hrs.
 Artesian flow g.p.m.

Temperature of water 48 Depth artesian flow encountered

(9) CONSTRUCTION:

Well seal—Material used CEMENT
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 6 9 in.
 Diameter of well bore below seal in.
 Number of sacks of cement used in well seal 6 sacks
 Number of sacks of bentonite used in well seal sacks
 Brand name of bentonite
 Number of pounds of bentonite per 100 gallons
 of water lbs./100 gals.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number 605
NW 1/4 NE 1/4 Section 33 T. 34S R. 6W. W.M.
 Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 72 ft.
 Static level 13 ft. below land surface. Date 7-22-72
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
 Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|------------------------------|-----------|-----------|-----------|
| <u>BRN CLAY-24" BOULDERS</u> | <u>0</u> | <u>13</u> | |
| <u>DECOMPOSED GRANITE</u> | <u>13</u> | <u>80</u> | <u>13</u> |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Work started 7/21 19 72 Completed 7/22 19 72
 Date well drilling machine moved off of well 7/22 19 72

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W. J. Sander Date 9-5-72
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 605

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Coleman's Well Drilling
 (Person, firm or corporation) (Type or print)

Address 2060 Vine, Grants Pass, Oreg.

[Signed] Joseph E. Blum
 (Water Well Contractor)

Contractor's License No. 380 Date 9-5-72