

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion

JOSE WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

FEB 14 1979

State Well No. 365/6 w-20ad

State Permit No.

2546
Rogue Review Park

WATER RESOURCES DEPT.
SALEM, OREGON
LEONARD RD

(1) OWNER:

Name RIVERIA MOBIL HOME PARK
Address 5076 LEONARD RD
GRANTS PASS, OREGON 97526

(10) LOCATION OF WELL:

County JOSEPHINE Driller's well number
SE 1/4 NE 1/4 Section 20 T. 36 R. 6 W.M.
Bearing and distance from section or subdivision corner
TAX LOT 1000

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 74 ft.
Static level 22 ft. below land surface. Date 2/7/79
Artesian pressure _____ lbs. per square inch. Date _____

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

8" Diam. from 0 ft. to 100 ft. Gage 250
Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>CLAY, BROWN</u>	<u>0</u>	<u>27</u>	
<u>CLAY, BEN, GRAVEL, Lg</u>	<u>27</u>	<u>74</u>	
<u>GRAVEL, Lg, SANDY</u>	<u>74</u>	<u>125</u>	<u>22'</u>
<u>AQUIFER</u>	<u>74</u>	<u>125</u>	<u>130 gpm</u>

(6) PERFORATIONS:

Type of perforator used TRECH
Perforated? Yes No.
Size of perforations 3/8 in. by 3 in.
400 perforations from 70 ft. to 100 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a DR test made? Yes No If yes, by whom? DRILLER
Flow: 130 gal./min. with _____ ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 50° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 29 sacks
How was cement grout placed? PUMPED
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Work started 2/6 1979 Completed 2/7 1979
Date well drilling/machine moved off of well 2/7 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] D. F. Orant Date 2/7, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 810

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name PAQUIN DRILLING INC
(Person, firm or corporation) (Type or print)

Address 1840 WILLOW LN GP

[Signed] Robert E. Quirin
(Water Well Contractor)

Contractor's License No. 675 Date 2-9, 1979