

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

NOV 19 1966 WATER WELL REPORT

Jose 28

State Well No. 34/5w-31 J
TAX LOT #900
State Permit No.

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON
(Please type or print)

(1) OWNER:

Name Carl Husen
Address 2727-Jumpoff Joe Creek Road
Grants Pass, Oregon.

(2) LOCATION OF WELL:

County Josephine Driller's well number -28-
N-E 1/4 S-E 1/4 Section 31 T. 34-S R. 5-W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 50'6" ft. Gage .250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & Sand.
Depth of seal 18' ft. Was a packer used? Steel
Diameter of well bore to bottom of seal 12" in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 18' ft. below land surface Date 11-1-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 42 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 58 ft. Depth of completed well 58 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Red Granite Top Soil With Some fine Gravel	0	5
Course Gravel & Red Decomposed Granite.	5	12
Small Boulders & Decomposed Red Gravel & Red Clay.	12	21
Small Gravel & Grey Decomposed Granite.	21	30
95%-Sticky White Granite Clay & White Decomposed Granite	30	55
Course Grey Granite Hard Pan	55	58

Work started 10-31-66 19 Completed 11-1-66 19
Date well drilling machine moved off of well 11-1-66 19

(13) PUMP:

None Installed as yet
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Les-Shanahan-Water-Well-Drilling-Co
(Person, firm or corporation) (Type or print)
Address 868-N-E-"A"-St-Grants Pass, Ore.

Drilling Machine Operator's License No. -98-

[Signed] Les Shanahan
(Water Well Contractor)

Contractor's License No. -81- Date 11-2-66 19