

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

OCT 3 1974

State Well No. 365/6W-15 ba

JOSE 3909

STATE ENGINEER SALEM, OREGON

State Permit No.

(1) OWNER:

Name Pat Patterson Address Lower River Rd. Grants Pass, Oregon

(10) LOCATION OF WELL:

County Josephine Driller's well number NE 1/4 NW 1/4 Section 15 T. 36S R. 6W W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 93 ft. Static level 7 ft. below land surface. Date 9-6-74 Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL:

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [X] 6" Diam. from 0 ft. to 101 ft. Gage 0.025

(12) WELL LOG:

Diameter of well below casing --- Depth drilled 100 ft. Depth of completed well 100 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

PERFORATIONS:

Perforated? [X] Yes [] No.

Type of perforator used Torch Size of perforations 1/4 in. by 4 in. 28 perforations from 93 ft. to 100 ft.

Table with columns: MATERIAL, From, To, SWL. Content: Conglomerate, 0, 100, 7

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 20 gal./min. with 92 ft. drawdown after 2 hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

Work started 8-23-1974 Completed 9-6-1974 Date well drilling machine moved off of well 9-6-1974

(9) CONSTRUCTION:

Well seal-Material used Cement Well sealed from land surface to 18 ft. Diameter of well bore to bottom of seal 7 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 6 sacks Number of sacks of bentonite used in well seal Brand name of bentonite Number of pounds of bentonite per 100 gallons of water lbs./100 gals. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] D. Keith Coleman Date 9-25, 1974 (Drilling Machine Operator) Drilling Machine Operator's License No. 822

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name Coleman's Well Drilling (Person, firm or corporation) (Type or print) Address 2060 NW Vine Grants Pass [Signed] Joseph E. Blum (Water Well Contractor) Contractor's License No. 380 Date 9-25-1974