

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON JUN 11 1974  
STATE ENGINEER  
SALEM, OREGON  
(Please type or print)  
(Do not write above this line)

State Well No. 3165/SW-636  
State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name Tom Hies  
Address 2202 N.W. Highland  
Grants Pass, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 92 ft. Gage 0.25  
" Diam. from " ft. to " ft. Gage  
" Diam. from " ft. to " ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used Torch  
Size of perforations 1/4 in. by 4 in.  
39 perforations from 25 ft. to 91 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " " "  
" " " " " " "  
" " " " " " "  
Bailer test 40 gal./min. with 96 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 9 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 5 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons  
of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Josephine Driller's well number  
NW 1/4 NE 1/4 Section 6 T. 365 R. 5W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 102 ft.  
Static level 6 ft. below land surface. Date 4-26-74  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 6"  
Depth drilled 104 ft. Depth of completed well 104 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Decomposed Granite + Clay</u>	<u>0</u>	<u>25</u>	—
<u>Decomposed Granite</u>	<u>25</u>	<u>104</u>	<u>6</u>

Work started 4-24 1974 Completed 4-26 1974  
Date well drilling machine moved off of well 4-26 1974

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Arman P. Fran Cisco Date 5-28, 1974  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 850

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Coleman's Well Drilling (Type or print)  
(Person, firm or corporation)

Address 2060 N.W. Vine, Grants Pass

[Signed] Joseph E. Plummer (Water Well Contractor)

Contractor's License No. 380 Date 5-28-, 1974