

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

MAR 13 1975

365/GW-24

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

fore
4234

STATE OF OREGON
(Please type or print) STATE ENGINEER

State Well No.

State Permit No.

SALEM, OREGON

(1) OWNER:

Name Fern Dixon
Address 1227 Redwood Ave
Grants Pass, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 62 ft. Gage .025
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Torch
Size of perforations 1/4 in. by 4 in.
36 perforations from 52 ft. to 58 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
d: _____ gal./min. with _____ ft. drawdown after _____ hrs.
"
"
Bailer test 20 gal./min. with 19 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number
1/4 1/4 1/4 Section 24 T. 365 R. 6W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 55 ft.
Static level 29 ft. below land surface. Date 1-24-75
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 59 ft. Depth of completed well 59 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	—
Decomposed Granite and Gravel 1/4"-1"	2	59	29

Work started 1-21-1975 Completed 1-24-1975
Date well drilling machine moved off of well 1-24-1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James A. Bower Date 2-26- 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 939

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Coleman's Well Drilling Company
(Person, firm or corporation) (Type of print)
Address 2060 N.W. Vine Grants Pass
[Signed] Joseph C. Bower
(Water Well Contractor)
Contractor's License No. 580 Date 1-27-76, 1976