NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT CEIVED

STATE OF OREGON JUL2 2 1974 State Well No. 365/6W-25da (Please type or print)

(1) OWNER:	(10) LOCATION, OF WELL:	
Name Bon Nunn	County Osephne Driller's well number	
Address 1930 Redwood Ave	NE 1/4 SE 1/4 Section 2,5 T, 36-S R. 6W W.M.	
Grants Pass, Oregon	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):		-
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐		_ `
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):		
		**
Cable Jetted	Static level /6 ft. below land surface. Date	
Dug 🛘 Bored 🗍 Irrigation 🖨 Test Well 🗍 Other 🔝	Artesian pressure Ibs. per square inch. Date	
CASING INSTALLED: Threaded [] Welded M. Welded M. Gage 1025	(12) WELL LOG: Diameter of well below casing	
"Diam from ft. to ft. Gage	Depth drilled ft. Depth of completed well ft	<u>.</u>
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials	
Didni, Holli	and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change in	
PERFORATIONS: Perforated? X Yes \(\square\) No.	position of Static Water Level and indicate principal water-bearing strata	ı.
Type of perforator used Torch	MATERIAL From To SWL	
Size of perforations 1/4 in. by 4 in.	Decomposed Granite 0 220 16	_
20 perforations from 68 ft. to 78 ft.	Black Rock 220 287 16	
perforations from ft. to ft.		_
perforations from		
		_
(7) SCREENS: Well screen installed? ☐ Yes 💢 No		_
Manufacturer's Name		_
Type Model No.		_
Diam. Slot size Set from ft. to ft.		_
Diam. Slot size Set from ft. to ft.		_
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		_
Was a pump test made? Yes No If yes, by whom?		_
Yield: gal./min. with ft. drawdown after hrs.		_
" " "		-
" " "		
Bailer test 20 gal./min. with 21 ft. drawdown after 2 hrs.		
Artesian flow g.p.m.		_
perature of water Depth artesian flow encountered ft.	Work started 5-13- 1974 Completed 5-18 1976	Z
(9) CONSTRUCTION:	Date well drilling machine moved off of well 2, -/2- 19/4	<u> </u>
Well seal-Material used	Drilling Machine Operator's Certification:	_
Well sealed from land surface toft.	This well was constructed under my direct supervision Materials used and information reported above are true to m	
Diameter of well bore to bottom of seal in.	best knowledge and belief.	٠,
Diameter of well bore below seal	[Signed]	4.
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No850	
Number of sacks of bentonite used in well seal sacks	Drining Machine Operagor's Excense No.	_
Brand name of bentonite	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report i	is
of water lbs./100 gals.	true to the best of my knowledge and belief.	
Was a drive shoe used? ★ Yes □ No Plugs Size: location ft. Did any strata contain unusable water? □ Yes ★ No	Name Coleman's Well Drilling (Person, firm or corporation) (Tope or print)	
Type of water? depth of strata	Address 2060 N.W. Vine Grants Pass	•••
	0 400	۔ ۔
Method of sealing strata off	[Signed] (Water Well Contractor)	_
Was well gravel packed? Yes No Size of gravel:		12
Gravel placed from ft. to ft.	Contractor's License No. 380. Date 6-21-, 19.7	<u>.</u> 7