

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
 JUL 21 1965
WATER WELL REPORT

STATE OF OREGON
 STATE ENGINEER (Please type or print)

Jose
 4437

State Well No. 36/60-27 G(1)
 State Permit No. _____

(1) OWNER: ROGUE COMM COLLEGE
 Name H.S. B.L.M.
 Address FORT UANBY
GRANTS PASS OREGON

(2) LOCATION OF WELL:
 County Josephine Driller's well number _____
SW 1/4 NE 1/4 Section 27 T.36 R.6W W.M.
 Bearing and distance from section or subdivision corner
41 FT. WEST OF EAST FENCE LINE
MOVED NORTH 3 FT. AWAY FROM
SEE.

(3) TYPE OF WORK (check):
 Well Deepening Reconditioning Abandon
 Upon abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0 ft. to 561.7 ft. Gage 40.500.
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used Slotted w/ Torch
 Size of perforations 1/8" in. by 16 in.
40 perforations from 40.7 ft. to 56.0 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____
 Model No. _____
 Diam. Slot size _____ Set from _____ ft. to _____ ft.
 Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal Cement Grout
 Depth of seal 20 ft. Was a packer used? No
 Diameter of well bore to bottom of seal .19 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? Flash Depth of strata 42-58'
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 28.7 ft. below land surface Date 5.7.65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 26 gal./min. with 26.8 ft. drawdown after 1 1/4 hrs.
"28 " 531.6 " 5 "
"30+plus " 80.3 " _____ "
 Baller test _____ gal./min. with _____ ft. drawdown after 4 1/2 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 12"
 Depth drilled 181.0 ft. Depth of completed well 181 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Decomposed Granite</u>	<u>0'</u>	<u>28</u>
<u>HARD GRANITE</u>	<u>28</u>	<u>42</u>
<u>Med. HARD GRANITE</u>	<u>42</u>	<u>58</u>
<u>w/ soft pockets</u>		
<u>Blue Grey GRANITE HARD</u>	<u>58</u>	<u>66</u>
<u>Med HARD</u>	<u>66</u>	<u>76</u>
<u>HARD Grey GRANITE</u>	<u>76</u>	<u>79</u>
<u>Med HARD GRANITE</u>	<u>79</u>	<u>92</u>
<u>HARD GRANITE</u>	<u>92</u>	<u>98.5</u>
<u>Med HARD GRANITE</u>	<u>98.5</u>	<u>123.0</u>
<u>HARD GRANITE</u>	<u>123</u>	<u>137.5</u>
<u>Med HARD GRANITE</u>	<u>137.5</u>	<u>181</u>
<u>WAT</u>		

Work started 9 APR 17 1965 Completed _____ 19____
 Date well drilling machine moved off of well 25 MAY 1965

(13) PUMP:
 Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.R. ILLI (Type or print)
 (Person, firm or corporation) (Type or print)
 Address 3401 NE 130 AVE PORTLAND
 Drilling Machine Operator's License No. 299
 [Signed] W.R. Illi
 (Water Well Contractor)
 Contractor's License No. 405 Date 7-19, 1965