JOSE 4777

Jose 4777

RECEIVED
MAY 11 1967
STATE ENGINEER
SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

# WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 36/6w-35d b
T.L. 1302 State Permit No.

## (1) OWNER:
Name County Squire Homes
Address 350 Redpine Drive
Grants Pass, Oregon

## (2) LOCATION OF WELL:
County Josephine Driller's well number
N.E. ¼ S.E. ¼ Section 35 T. 36S R. 6W W.M.
Bearing and distance from section or subdivision corner.
2389 Sand Creek Road
Grants Pass, Oregon

## (3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

## (4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

## (5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

## (6) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 71 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

## (7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Gen.
Size of perforations ⅛ in. by 4 in.
40 perforations from 66 ft. to 71 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

## (8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

## (9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

## (10) WATER LEVELS:
Static level 25 ft. below land surface Date May 3/67
Artesian pressure lbs. per square inch Date

## (11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 30 ft. drawdown after 1½ hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? ☐ Yes ☒ No

## (12) WELL LOG:
Diameter of well below casing 6
Depth drilled 70 ft. Depth of completed well 70 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

| MATERIAL | FROM | TO |
|---|---|---|
| Red Clay - Sand - Soil | 0 | 17 |
| Tan D. G. | 17 | 38 |
| Brown D. G. | 38 | 48 |
| Tan Brown D. G. | 48 | 58 |
| Hard white + black D. G. - Coarse Sand | 58 | 70 |

Work started April 29 1967 Completed May 3 1967
Date well drilling machine moved off of well May 3 1967

## (13) PUMP:
Manufacturer's Name
Type: H.P.

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BROWNER'S WELL DRILLING
(Person, firm, or corporation) (Type or print)
Address 525 N.E. "E" ST. GRANTS PASS, OREGON
Drilling Machine Operator's License No. 346
[Signed] Homer A. Browner
(Water Well Contractor)
Contractor's License No. 414 Date May 6, 1967

(USE ADDITIONAL SHEETS IF NECESSARY)