RECEIVED
MAY 17 1960
STATE ENGINEER
SALEM, OREGON

JOSE 4971

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 36/6W-23

State Permit No.

(1) OWNER:
Name MRS. C. F. BROWN
Address 1330 WILLOW LANE
GRANTS PASS. ORE

(2) LOCATION OF WELL:
County Josephine. Owner's number, if any—
¼ ¼ Section 23 T. 36 R. 6-5 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
6" Diam. from 0 ft. to 28" ft. Gage 188
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? Depth of strata
Method of sealing strata off Std. Dr. Shoe

(10) WATER LEVELS:
Static level ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Curtis F. Brown (Owner) Date May 2-, 1960

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 40 gal./min. with NO ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well 6 inches.
Depth drilled 30 ft. Depth of completed well 30 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	2
Dk Comp Sht	2	6
Sandy Loam	6	16
Cement Rv	16	28
Water Gravel & Sand	28	30

Work started 5-1 1960 Completed 5-2 1960

(13) PUMP:
Manufacturer's Name ADVANCE
Type: Vertical H.P. 1/3

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Pat Arnot Drilling Co (Person, firm, or corporation) (Type or print)
Address 1553 Redwood Ave
Driller's well number
[Signed] P. Arnot (Well Driller)
License No. 51 Date 5/2, 1960

(USE ADDITIONAL SHEETS IF NECESSARY)