

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

OCT 7 1966 WATER WELL REPORT

JOSE 5503

State Well No. 35/7w-4L

STATE OF OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name Josephine County Parks
Address Courthouse
Quants Pass, Ore.

(2) LOCATION OF WELL:

County Joseph. Driller's well number I.M.P. #2
NE 1/4 S10 1/4 Section 4 T. 35 S. R. 7 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [x] Deepening [] Reconditioning [] Abandon []
abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [x] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 57 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [x] Yes [] No
Type of perforator used torch
Size of perforations 4 in. by 3/4 in.
36 perforations from 50 ft. to 55 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [x] Yes [] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 43' ft. below land surface Date 9/1/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [x] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 20 gal./min. with 10 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 72 ft. Depth of completed well 72 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries: fine sand (0-12), conglomerate (12-56), soft black rock (56-72)

Work started 8/28 1966 Completed 9/1 1966
Date well drilling machine moved off of well 9/1 1966

(13) PUMP:

Manufacturer's Name Myers
Type: Jet H.P. 1 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Coleman's Well Drill (Person, firm or corporation) (Type of print)
Address 2060 Union St.
Drilling Machine Operator's License No. 317
[Signed] J.E. Plummer (Water Well Contractor)
Contractor's License No. 380 Date 10/5 1966