

RECEIVED
APR 19 1960
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT STATE OF OREGON

JOSE 5904

35/7W-4 ✓

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No.

State Permit No.

(1) OWNER:

Name Josephine County
Address Grants Pass, Oregon

(2) LOCATION OF WELL:

County JOSE Owner's number, if any—
1/4 SW 1/4 Section 4 T. 35S R. 7W W.M.
Bearing and distance from section or subdivision corner
Indian Mary Park

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 60 ft. Gage 2/16
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Torch
SIZE of perforations 4 in. by 3/4 in.
30 perforations from 55 ft. to 60 ft.
20 perforations from 35 ft. to 40 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name Model No.
Type
Diameter Slot size Set from ft. to ft.
..... Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: 2/4
Gravel placed from 10 ft. to 60 ft.
Was a surface seal provided? Yes No To what depth? 10 ft.
Material used in seal— Clay & Rock
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 3/28/60
Artesian pressure lbs. per square inch Date

Log Accepted by: R. Kubin

[Signed] Date 4/14, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 30 gal./min. with 10 ft. drawdown after 4 hrs.
" " " " " "
" " " " " "

Bailer test 45 gal./min. with 10 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 78 ft. Depth of completed well 78 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Red Clay</u>	<u>0</u>	<u>23</u>
<u>Sand & Gravel</u>	<u>23</u>	<u>60</u>
<u>Shale</u>	<u>60</u>	<u>78</u>

Work started 3-23-60 Completed 3/28 1960

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Colman's Well Drilling
(Person, firm, or corporation) (Type or print)

Address 110 N.W. Morgan Lane

Driller's well number

[Signed] Joseph C. Colman
(Well Driller)

License No. 114 Date 4/14, 1960