NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED NOV 24 1971 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

JOSC 6086

State Well No. 39/7W-31CC

State Permit No.

(1) OWNER:
Name Raymond Gibson
Address 32428 Redwood Hwy. O'brien - Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 80 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Cutting Torch
Size of perforations 3/16 in. by 4 in.
90 perforations from 40 ft. to 80 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 25 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 50 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal None sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4 Minus
Gravel placed from 20 ft. to 80 ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number
S.W. ¼ S.W. ¼ Section 31 T. 39 R. 7 W.M.
Bearing and distance from section or subdivision corner
TL 215

(11) WATER LEVEL: Completed well.
Depth at which water was first found 30 ft.
Static level 15 ft. below land surface. Date 9-27-71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay & Boulders (Med)	0	20	15
Clay & Med. Gravel	20	35	
Fine Blue Sand & Lg. Gravel	35	60	
Med. Gravel - Water Bearing	60	80	

Work started 9-27 19 71 Completed 10-1 19 71
Date well drilling machine moved off of well 10-1 19 71

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] R. Roy Clouse (Drilling Machine Operator) Date 11-17, 19 71
Drilling Machine Operator's License No. 773

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ross Swartz (Person, firm or corporation) South State Drilling Co (Type or print)
Address 823 Summit Loop, Grants Pass Ore.
[Signed] Ross Swartz (Water Well Contractor)
Contractor's License No. 450 Date 11-17, 19 71

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119