RECEIVED
MAY 11 1967
STATE ENGINEER
SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

JOSE 6247

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 37/6W-12B
State Permit No.

(1) OWNER:
Name Homer G Browner
Address 1314 N. E. 10th Street
Grants Pass, Oregon

(2) LOCATION OF WELL:
County Josephine Driller's well number
N.W. ¼ N.E. ¼ Section 12 T. 37S R. 6 W W.M.
Bearing and distance from section or subdivision corner
Joyce Drive

(3) TYPE OF WORK (check):
Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 160 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Gas
Size of perforations 1/8 in. by 4 in.
40 perforations from 155 ft. to 160 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 40 ft. below land surface Date April 20/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 102 ft. drawdown after 1½ hrs.
Artesian flow g.p.m. Date
Temperature of water 52° Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing 6 in.
Depth drilled 167 ft. Depth of completed well 167 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
D. G. Tan Granite	0	40
D. G. Orange Granite	40	159
White + black-med granite rock	159	167

Work started April 12 1967 Completed April 20 1967
Date well drilling machine moved off of well April 20 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BROWNER'S WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 525 N. E. "E" ST. GRANTS PASS, OREGON
Drilling Machine Operator's License No. 346
[Signed] Homer G Browner
(Water Well Contractor)
Contractor's License No. 414 Date April 24, 1967

(USE ADDITIONAL SHEETS IF NECESSARY)