

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

NAME OF SELLER
(Please type or print)

State Permit No.

Name Country Square Homes
Address 350 Adeline Drive
Grant Pass, Oregon

County Josephine Driller's well number
 T. 14 S. R. 6 W. W.M.
 Bearing and distance from section or subdivision corner

110 Honey Lane Home Lot 118 of
1st. Sub. Div. of Homplotts off
of new Hope Rd., Southwest of
Greets Pass

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

Domestic ☒ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Irrigation ☐ Test Well ☐ Other ☐ Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
 6" Diam. from 0 ft. to 144 ft. Gage 250
 " Diam. from " ft. to " ft. Gage "
 " Diam. from " ft. to " ft. Gage "

Perforated? ☒ Yes ☐ No

Type of perforator used			
Size of perforations	in.	by	in.
40	1/8	4	
perforations from	139	ft. to	144
perforations from		ft. to	
perforations from		ft. to	
perforations from		ft. to	
perforations from		ft. to	

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

Well seal—Material used in seal Bentonite

Depth of seal18..... ft. Was a packer used?

Diameter of well bore to bottom of seal10..... in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Static level 47 ft. below land surface Date April 29/67
Artesian pressure _____ lbs. per square inch Date _____

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____

Yield:	gal./min. with	ft. drawdown after	hrs.
--------	----------------	--------------------	------

" " " "

“ “ “ “

Bailer test 1.3 gal./min. with 78 ft. drawdown after 1 1/2 hrs.

Artesian flow g.p.m. Date _____

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

Diameter of well below casing 6

Depth drilled 144 ft. Depth of completed well 144 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started April 20 19 67 Completed April 29 19 67
Date well drilling machine moved off of well April 29 19 67

Manufacturer's Name

Type: **HP**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

BROWNER'S WELL DRILLING
NAME 525 N. E. "E" ST.
(Person, firm or corporation) (Type or print)

Address GRANT'S PASS, OREGON

Drilling Machine Operator's License No. 346

[Signed] James H. Browne
(Water Well Contractor)

Contractor's License No. 414 Date April 29, 1962

(USE ADDITIONAL SHEETS IF NECESSARY)