

RECEIVED
OCT 5 1959

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 37/6W-13D

State Permit No.

(1) OWNER:

Name: Frank Morgan
Address: 1017-Fruitdale Drive, (New Hope Property)
Grants Pass, Oregon.

(2) LOCATION OF WELL:

County: Josephine
Owner's number, if any--
Section 13 T. 37 R. 6 W.M.
Bearing and distance from section or subdivision corner
19 rods west from east line
30 rods south of north line

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
Diam. from 0 ft. to 107 ft. Gage .288
Diam. from ft. to ft. Gage
Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 106 ft.
Material used in seal - $\frac{3}{4}$ "-Drive Shoe & Casing.
Did any strata contain unusable water? Yes No
Type of water? Dirty Depth of strata 20'
Method of sealing strata off Casing

(10) WATER LEVELS:

Static level 18 ft. below land surface Date 9/21/59
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Frank Morgan Date Oct 2, 1959
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield gal./min. with ft. drawdown after hrs.
Baller test 25 gal./min. with 75 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Red Loam & Granite Top Soil.	0	3
Brown Decomposed Granite	3	20
Dirty Brown Decomposed Granite	20	45
Clean Decomposed Brown Granite	45	100
Mixture of Clean Sharp Grey & Brown Granite Hardpan.	100	115

Work started 9/15/59 19 Completed 9/21/59 19

(13) PUMP:

Manufacturer's Name Peerless
Type: Jet H.P. 1

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Les-Shanahan-Drilling-Company.
(Person, firm, or corporation) (Type or print)
Address 868-N-E-"A"-St, Grants Pass, Oregon.

Driller's well number -31-
[Signed] Les Shanahan (Well Driller)
License No. -81- Date 9/22/59, 19