NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
SEP 10 1971
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Jose 6417

State Well No. 38/8W-11ac
State Permit No.

(1) OWNER:
Name Warren N. Morse
Address Selma, Oregon 97538

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 60 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Cutting Torch
Size of perforations 3/16 in. by 8 in.
45 perforations from 40 ft. to 60 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 8 gal./min. with 42 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 58 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used ~~Cement~~ Cemente Gr.
Well sealed from land surface to 20 FT. ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal None sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No. Size of gravel: 3/4 minus
Gravel placed from 20 ft. to 60 ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number
S.W. ¼ N.E. ¼ Section 11 T. 38 R. 8 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 32 ft.
Static level 18 ft. below land surface. Date 7-30 to 8-71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing ~~10~~
Depth drilled 60 ft. Depth of completed well 60 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
~~0 — 2~~			
Clay + Gravel	0	22	18
Med. Gravel & Sand	23	30	
Med. Gravel - Water Br.	31	50	
Med. Gravel - Water Br.	57	60	

Work started 7-27 19 71 Completed 7-31 19 71
Date well drilling machine moved off of well 8-2 19 71

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ray H. Clouse Date Sept 4, 19 71
(Drilling Machine Operator)
Drilling Machine Operator's License No. 573

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name South State Drilling
(Person, firm or corporation) (Type or print)
Address 825 Summit Loop, Grants Pass Ore. 97526
[Signed] Ross Scranton
(Water Well Contractor)
Contractor's License No. 452 Date Sept 4, 19 71

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45556-119