

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT NOV 19 1974

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON STATE ENGINEER State Well No. 395/8W-22
(Please type or print) SALEM, OREGON State Permit No. _____
(Do not write above this line)

SCHOOL

CAVE JUNCT

(1) OWNER:

Name Josephine Co. School Dist.
Address 714 NW. 7th Grants Pass, Or

(10) LOCATION OF WELL:

County Josephine Driller's well number _____
1/4 Section 22 T. 39-5 R. 9W. W.M. _____
Bearing and distance from section or subdivision corner _____

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(11) WATER LEVEL: Completed well.

Depth at which water was first found 130 ft.
Static level 45' ft. below land surface. Date 11-9-74
Artesian pressure _____ lbs. per square inch. Date _____

CASING INSTALLED:

Threaded Welded
6 Diam. from 0 ft. to 127 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 155 ft. Depth of completed well 155 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

MATERIAL	From	To	SWL
Red CLAY	0	25	
Green CLAY	25	40	
Red CLAY GRAVEL SM	40	45	
Blue CLAY	45	107	
FRACT CLAYSTONE BLACK FIRM	107	121	
FRACT CLAYSTONE (BLACK) HARD	121	155	
STRATA	130	140	38

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 38 gal./min. with 66 ft. drawdown after 1 hrs.
" " " " " " " "
" " " " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 49.0 Depth artesian flow encountered _____ ft.

Work started 11-6 19 74 Completed 11-9 19 74
Date well drilling machine moved off of well 11-9 19 74

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 70 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 67 sacks
Number of sacks of bentonite used in well seal 6 sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] G. E. Quinn Date 11-10 19 74
(Drilling Machine Operator)
Drilling Machine Operator's License No. 855

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name JA. Quinn Drilling Co.
(Person, firm or corporation) (Type or print)
Address 1840 Willow Ln Grants Pass, Ore
[Signed] C. J. Oserstetter
(Water Well Contractor)
Contractor's License No. 546 Date 11/15 19 74