

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED FEB 26 1969 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

STATE OF OREGON (Please type or print) not write above this line

State Well No. 39/8W-28 bdc State Permit No.

JOSE 6642

(1) OWNER:

Name J.A. Schuler Address 1833 Fairview Dr Grants Pass

(11) LOCATION OF WELL:

SW Josephine Driller's well number NE 1/4 NW 1/4 Section 28 T. 29S R. 8W W.M. Bearing and distance from section or subdivision corner Tax lot 900 42.14890000 -123.65365000 27550 REDWOOD HWY, CAVE JUNCTION OR 97523

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(12) WELL LOG:

Diameter of well below casing --- Depth drilled 106 ft. Depth of completed well 106 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Red Clay, Blue Clay, Medium Gravel.

CASING INSTALLED:

Threaded [ ] Welded [X] 1/4" 6" Diam. from 0 ft. to 106 ft. Gage 1/4"

PERFORATIONS:

Perforated? [X] Yes [ ] No. Type of perforator used Touch Size of perforations 4 in. by 1/4 in. 36 perforations from 100 ft. to 105 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 30 ft. below land surface Date 1/13/69 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Baller test 45 gal./min. with 51 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used Cement Depth of seal 18 ft. Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Work started 1/3 1969 Completed 1/13 1969 Date well drilling machine moved off of well 1/13 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J.W. Holbrook Date 2-24-69 (Drilling Machine Operator)

Drilling Machine Operator's License No. 351

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Colemans Well Drilling (Person, firm or corporation) (Type or print)

Address 2060 Vine ST

[Signed] Joseph E. Coleman (Water Well Contractor)

Contractor's License No. 380 Date 2-24, 1969