

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with me

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

NOV 14 1977

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

Case 7299

State Well No. 365/W-2100

State Permit No.

WATER RESOURCES DEPT.

(1) OWNER:

SALEM, OREGON Spalding & Son 2345 SE "N" Street Grants Pass, OR

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(3) TYPE OF WELL:

Rotary [X] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [X] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 14.5 ft. Threaded [ ] Welded [X] Gage 2.50

(6) PERFORATIONS:

Perforated? [ ] Yes [X] No

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Air test 35 gal./min. with 100 ft. drawdown after 1 hrs.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout Well sealed from land surface to 40 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. 11 Number of sacks of cement used in well seal sacks How was cement grout placed? Grout pump and drop pipe.

Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number NE 1/4 NE 1/4 Section 21 T. 36S R. 5W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft. Static level 50 ft. below land surface. Date 10/15/77 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6. Depth drilled 160 ft. Depth of completed well 160 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Clay, brown & Boulders, Clay, brown impervious, Clay, brown w/boulders, Rock, gray hard w/fractures.

Work started 10/14 19 77 Completed 10/15 1977 Date well drilling machine moved off of well 10/15 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Robert Everett Date 11/10, 1977 (Drilling Machine Operator) Drilling Machine Operator's License No. 695

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name McClanahan Well Drilling (Person, firm or corporation) (Type or print) Address 141 NE Beacon Drive Grants Pass, OR [Signed] (Water Well Contractor) Contractor's License No. 614 Date November 11, 1977