

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

RECEIVED

DATE OF OREGON  
(Please type or print)

OCT 4 1977 (Do not write above this line)

State Well No. 36/SW-29dd  
State Permit No. 1936

(1) OWNER:

WATER RESOURCES DEPT.  
SALEM, OREGON

Name Doug Robertson  
Address 2387 Cloverlawn - Grants Pass, OR

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

6" Diam. from 0 ft. to 40 ft. Threaded  Welded   
Gage .250  
....." Diam. from ..... ft. to ..... ft. Gage .....  
....." Diam. from ..... ft. to ..... ft. Gage .....

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name .....  
Type ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
~~Water~~ test 50 gal./min. with 65 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ..... ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout  
Well sealed from land surface to 40 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 10 sacks  
How was cement grout placed? Grout pump and drop pipe

Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number  
SE 1/4 SE 1/4 Section 29 T. 36S R. 5W W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found ..... ft.  
Static level 25 ft. below land surface. Date 9-23-77  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing ..... 6

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Clay, brown &amp; gravel</u>	<u>0</u>	<u>32</u>	
<u>Granite, hard, gray</u>	<u>32</u>	<u>50</u>	
<u>/Granite, hard, gray w/fracture</u>	<u>50</u>	<u>100</u>	<u>25</u>

Work started 9/23 19 77 Completed 9/23 1977  
Date well drilling machine moved off of well 9/23 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] ..... Date 9/28, 1977.  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 674

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name McClanahan Well Drilling  
(Person, firm or corporation) (Type or print)  
Address 141 NE Beacon Dr., Grants Pass, OR  
[Signed] .....  
(Water Well Contractor)  
Contractor's License No. 614 Date 9/28, 1977