

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

State Well No. 355/bw-2000

JUL 26 1978

State Permit No.

*John
S209*

(1) OWNER:

Name Luther Barker
Address 1530 Jenkins
Grants Pass, OR 97526

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

6 " Diam. from 0 ft. to 75 ft. Threaded Welded
Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Well: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " "
" " " " "
Air ~~pross~~ test 50 gal./min. with 80 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed?
Grout pump and drop pipe.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number 462-2
NE ¼ NW ¼ Section 20 T. 35 R. 6 W.M.
Bearing and distance from section or subdivision corner
Tax Lot 1300

(11) WATER LEVEL: Completed well.

Depth at which water was first found 75 ft.
Static level 40 ft. below land surface. Date 7/15/78
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay, brown & Gravel, sm/med & Boulders, small	0	15	
Clay, brown impervious	15	25	
Clay, blue impervious	25	35	
Clay, blue/grey & Boulders, sm/med & Gravel, med	35	60	
Granite, black/white fractured water bearing	60	100	40

Work started 7/14 1978 Completed 7/15 1978
Date well drilling machine moved off of well 7/15 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ray Weatherly Date 7/18, 1978
Drilling Machine Operator
Drilling Machine Operator's License No. 1234

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name McClanahan Well Drilling (Person, firm or corporation) (Type or print)
Address 141 NE Beacon Drive Grants Pass, OR
[Signed] George H. McClanahan (Water Well Contractor)
Contractor's License No. 422 Date July 18, 1978